

Alarm Check Valve

ITEM CODE: NewAge-AV-4/6



Description

- UL Listed
- Water working pressure rating : 75 psig (12.3 bar)
- Factory hydrostatic test pressure: 350 psig (24.6 bar)
- ANSI B16.5 Flanged inlet and outlet

Certificates



NKB House, Mehta Market, Surendranagar 363001 Gujarat, India
+91 2752 288000 | +91 9825209089
www.newage-india.in | info@newage-india.in